



PLAN

NOTE: ALL JOINTS STRAPPED AS REQUIRED

BILL OF MATERIAL
1.) T.S.&V.
2.) 2- COUPLINGS
3.) DETECTOR CHECK (3/4" METER)
4.) 10'-8" D.I.P. SHORT
5.) +40'-8" D.I.P. LONG

NOTE:

FOR WATER MAIN IN SIDEWALK METER MAY BE INSTALLED PARALLEL WITH WATER MAIN.

IF INSUFFICIENT AREA EXISTS WITHIN PUBLIC RIGHT-OF-WAY, A METER EASEMENT MUST BE PROVIDED.

DIMENSIONS (IN INCHES)				
DETECTOR CHECK SIZE	A	B	C	D
6"	22?	48	34	20
8"	26?	48	34	20
10"	26?	48	34	20

NOTE: THIS DRAWING FOR DESIGN INFORMATION ONLY UWSA FORCES WILL INSTALL ALL DETECTOR CHECK VALVES.

THIS DETAIL WAS TAKEN FROM THE CITY OF ATLANTA'S WEBSITE. IT MAY HAVE BEEN MODIFIED AND SHOULD BE REVIEWED THOROUGHLY.

<p>City of Atlanta</p> 	<p>STANDARD DETAILS</p>	<p>REV. DATE: OCT. 2011</p>
	<p>TYPICAL DETECTOR CHECK VALVE INSTALLATION</p>	<p>ORIG. DATE: NOV. 2004 SCALE: N.T.S.</p>
		<p>DETAIL NO. WR-G_VL004</p>