



NOTE: ALL JOINTS
STRAPPED AS REQUIRED

3 THROUGH 12" FIRE SERVICE LINE

BILL OF MATERIAL
1.) T.S.&V.
2.) 1-VALVE BOX
3.) 10'-8" D.I.P. SHORT
4.) 40'-8" D.I.P. LONG

NOTE:

FOR WATER MAIN IN SIDEWALK METER MAY BE INSTALLED PARALLEL WITH WATER MAIN.

IF INSUFFICIENT AREA EXISTS WITHIN PUBLIC RIGHT-OF-WAY, A METER EASEMENT MUST BE PROVIDED.

NOTE: THIS DRAWING FOR DESIGN INFORMATION ONLY UWSA FORCES WILL INSTALL ALL DETECTORS CHECK VALVES.

THIS DETAIL WAS TAKEN FROM THE CITY OF ATLANTA'S WEBSITE. IT MAY HAVE BEEN MODIFIED AND SHOULD BE REVIEWED THOROUGHLY.

<p>City of Atlanta</p> 	<p>STANDARD DETAILS</p>	<p>REV.</p> <p>DATE: OCT. 2011</p> <p>ORIG. DATE: NOV. 2004</p> <p>SCALE: N.T.S.</p>
	<p>TYPICAL FIRE-SERVICE INSTALLATION</p>	<p>DETAIL NO. WR-G_SV003</p>