



NOTE:

1. FOR 1 1/2" AND 2-INCH SERVICES, MULTIPLE 1-INCH SERVICE LINES SHALL BE PROVIDED BETWEEN WATER MAIN AND WATER METER.
2. NEW SERVICE LINE UNDER ROADWAYS SHALL BE INSTALLED IN A CASING. REPLACEMENT SERVICE LINES MAY BE INSTALLED BY FREE BORE IF EXIST SERVICE IS NOT CASING.

THIS DETAIL WAS TAKEN FROM THE CITY OF ATLANTA'S WEBSITE. IT MAY HAVE BEEN MODIFIED AND SHOULD BE REVIEWED THOROUGHLY.

City of Atlanta



STANDARD DETAILS

WATER SERVICE AND METER CONNECTION

REV.

DATE: OCT. 2011

ORIG. DATE: OCT. 2004

SCALE: N.T.S.

DETAIL NO. WR-G_SV004