



TYPE "A" FIRE HYDRANT (FH) LATERAL

NOTES:

1. ALL FERROUS SURFACES OF PIPE AND APPURTENANCES TO BE PROVIDED WITH PROTECTIVE COATINGS PER SPECS.
2. PROVIDE STAINLESS STEEL NUTS, BOLTS AND WASHERS TO BURIED FLANGES AND COUPLINGS, EXCEPT FOR NON-METALLIC WASHERS TO BE PROVIDED AS PART OF INSULATING FLANGE SET.

THIS DETAIL WAS TAKEN FROM THE CITY OF ATLANTA'S WEBSITE. IT MAY HAVE BEEN MODIFIED AND SHOULD BE REVIEWED THOROUGHLY.

| | | |
|--|--|---|
| <p>City of Atlanta</p>  | <p>STANDARD DETAILS</p> | <p>REV. DATE: OCT. 2011 ORIG. DATE: NOV. 2004 SCALE: N.T.S.</p> |
| | <p>TYPE "A" TYPICAL FIRE HYDRANT</p> | |